

Equipment Bracing System

Equipment cabinets and racks shall be braced in accordance with local codes. Cabinets braced at the top can utilize the cable ladder rack system, if present, with an attachment that provides rigid four-directional lateral bracing. Equipment mounted on access floors in seismic areas shall be braced to the underfloor slab with an approved method. The bases of cabinets and racks should be braced to the slab as appropriate for the seismic demand in accordance with local seismic codes or requirements.

Revision #1

Created 3 October 2025 11:27:23 by RISA

Updated 3 October 2025 11:27:34 by RISA