Fire Suppression Room

A separate room shall be provided for the pre action sprinkler control valve system for class 4 datacenter and a separate room is recommended for critical or Class 3 data centers.

Space shall be provided for the placement of clean agent fire suppression tanks as required. Tanks shall be located to assist easy serviceability. Tanks shall not be in the ceiling area above equipment.

Revision #1
Created 3 October 2025 11:10:01 by RISA
Updated 3 October 2025 11:10:17 by RISA