

# Mechanical Room

Outside of the computer room provide space for the heat ejection equipment and associated pumps, fuel tanks and controls.

Mechanical components within a computer room should be located separate from the ITE rows in order to provide maintenance access.

Cooling systems should be located separate from the ITE rows in order to provide for maintenance unless placement in or close to the ITE row is necessary for enhanced cooling effectiveness.

---

Revision #1

Created 3 October 2025 11:09:16 by RISA

Updated 3 October 2025 11:09:39 by RISA